



ETL Listed
 ETL Control # 3107144
 2 Hour Fire Wall Rating
 Conforms to UL Std. 514C
 $\frac{1}{2}$ " $\frac{3}{4}$ " and 1" concentric knockouts (one on each side of the wall, except on stud wall).
 22 Cubic Inch Nonmetallic ENT Switch/Outlet Box
 Mounts with flange along the side of the box



CANTEX

INC.
 Fort Worth, TEXAS

22 Cubic Inch ENT Electrical
 Single Gang Box

Drawn By: D. Gwinn

Date: 3/20/18

Ref. EN22SB